

(B) Bharat Bi	free	Data sheet		
Manufacturer	Bharat Bijlee Ltd.		Customer	
Type of motor	3 Phase Induction Motor		BBL Enquiry reference No	
Quantity			Customer P.O.Number	
Application	CUSTOM	ER TO FURNISH	W.O. No. / SAP No.	
Гag no.			Output kW / pole	0.55 / 4P
BBL type tef.			Frame size	80
nstallation detail	ls	1	Applicable standards (latest edition)	
Area classification	n (Safe / Hazardous)	Industrial safe area	Performance: IS15999-1 Maintenance IS:900	
Location: indoor/o	outdoor/dools	Indoor	Dimensions: IS 1231/IS 2223/IS:8223	
Altitude (meters)	outdool/deck	1000 or less	Vibrations: IS 12075	
dititude (meters)		1000 01 1035	Noise level: IS 12075	
Hazardous area a	letails		Supply conditions and permissible variations (grid	sunnly)
	n GAS (Zone 1/Zone 2)	N.A.	Number of phases	Three
Jas group	(, ,	N.A.	Voltage (Volts) and permisible variation	415 ±10%
Temp.class		N.A.	Frequency (Hz) and permissible variation	50 ±5%
•	n protection (FLP/Type			
e'/Type 'n')	i protection (i El / Type	N.A.	Combined variation (absolute sum)	±10%
Approving authori	ity for hazardous area	Not Applicable		
Electrical parame		<u> </u>		
tarting performa	ance			
Aethod of starting	g 5	DOL	Starting current (%FLC)	500
.oad speed (rpm)		CUSTOMER TO FURNISH	Starting torque (%FLT)	280
Aotor GD ² (kgm ²		0.0066	Pull out torque (%FLT)	300
Load $GD^2(kgm^2)$,	CUSTOMER TO FURNISH	Locked rotor withstand time (hot/cold) (sec)	30 / 60
Load torque-speed	d curve	Parabolic TS curve	Number of consecutive starts (hot/cold) (nos.) provided Load GD2 = Motor GD2	2/3
tarting time at ra	ted voltage (sec)	PLEASE FURNISH ALL ABOVE	provided Load GD2 = Motor GD2	
Running Perform	anco	DETAILS		
Efficiency class	unce	IE2	Duty and designation	Continuous (S1)
	mp.rise by resistance (deg.C)	50 / 70	CDF/Equivalent starts per hour/FI	-
ŕ	inp.rise by resistance (deg.e.)	TEFC (TOTALLY ENCLOSED		
Enclosure		FAN COOLED)	Insulation class / utilisation class on DOL	F/B
Full load current ((FLC) amps.	1.34	Rotor type (Squirrel Cage/ Slip ring)	Squirrel Cage
Full load speed (r	pm)	1420	Rotor voltage/rotor current (RV/RA) (Volts/Amps)	Not applicable
Full load torque (I		0.38	Stator/rotor time constant (min)	90/122
	FL/0.75FL/0.5FL	77.1 77.1 72.0	Power factor at FL/0.75FL/0.5FL	0.74 0.64 0.50
Mechanical para	meters			
/Iounting		B3	Mounting dimensions	Refer GA drawing
shaft extention		Single cylindrical	Direction of rotation viewed from DE	Clockwise
Degree of protecti	ion	IP 55	Suitable for bidirectional rotation	Yes
Aethod of cooling	g (TEFC/forced	TEFC (IC 411)	Paint type	Acrylic
ooled/TESC)	()			
Net weight of mot	tor (kgs.)	10	Paint shade	RAL 5000
Bearings			Earthing provision (two terminals on stator body) <i>Terminal box</i>	Yes
Coupling (Direct/	flexible/Belt &	Direct	Terminal box location when viewed from DE	As per GA drawing
ulley/Gearbox)		Ditte		
	alley (OD x width) mm	- Dall /Dall	Direction of cable entry	As per GA drawing
	all/angular contact)	Ball /Ball	Cable size and type(Aluminium)	1R X 3C X 4 SQ MM
Bearing size DE/N			Earthing provision (one terminal in TB) No of phases/Winding connection/number of	Yes
Type of lubrication		LITHIUM SOAP BASE GREASE	terminals	3 / STAR / 6
ccessories				
	s simplex (w/o controller)		Arrow plate for direction of rotation	
BTDs - 1 number	per bearing (w/o controller)		Double compression glands (main cable)	
pace heaters - sir	ngle phase 50z, 230V		Double compression glands (Space heater/thermisters/RTDs)	
Thermisters - PTC	C, 1 number per phase		Brake (Type/voltage/torque)	
Additional T-Box			() France (100, 100 June)	
Additional namep				
		L	1	
Notes:				

All performance values are subject to IS15999-1 tolerances, unless otherwise specified.
Performance values are at rated voltage and rated frequency condition and for DOL starting condition.
Motor GD² = Load GD² assumed wherever not mentioned.
Where starting time is more than 10 seconds, provision of heavy duty relays is mandatory.
Kilowatt rating is mandatory and HP is approximate.
Accessories provided are marked as "YES"


			Prepared by	
			Approved by	
			Revison	
Project:	Contractor/Client		Date:	
Consultant	Package			
	· · · · · · · · · · · · · · · · · · ·			



-	-	-	-
Rev No.	Prepared By	Checked By	Date



-	-	-	-
Rev No.	Prepared By	Checked By	Date



-	-	-	-
Rev No.	Prepared By	Checked By	Date