Bharat Bij	liee	Data sheet	t for motors		
	Bharat Bijlee Ltd.		Customer		
Type of motor 3	8 Phase Induction Motor		BBL Enquiry reference No		
Quantity			Customer P.O.Number		
Application	CUSTOM	ER TO FURNISH	W.O. No. / SAP No.		
Гag no.			Output kW / pole	132 /	6I
BBL type tef.			Frame size		315L
Installation details	<u>s</u>		Applicable standards (latest edition)		
Area classification	(Safe / Hazardous)	Industrial safe area	Performance: IS/IEC 60034-1 Maintenance IS:900		
Location: indoor/outdoor/deck		Indoor	Dimensions: IS 1231/IS 2223/IS:8223		
Altitude (meters)		1000 or less	Vibrations: IS 12075		
			Noise level: IS 12065		
Hazardous area de	etails	<u> </u>	Supply conditions and permissible variations (grid	t supply)	
Area classification GAS (Zone 1/Zone 2)		N.A.	Number of phases	1	Three
Gas group		N.A.	Voltage (Volts) and permisible variation	415 ±10%	
Femp.class		N.A.	Frequency (Hz) and permissible variation	50 ±5%	
	protection (FLP/Type	N.A.	Combined variation (absolute sum)	+	10%
'e'/Type 'n')		11.21.	combined variation (absolute sum)	-	10/0
Approving authorit	ty for hazardous area	Not Applicable			
0	-	Torrippieusie			
Electrical parame					
Starting performa		DOI	Statistics and (0/ FLO)		600
Method of starting		DOL CUSTOMER TO FURNISH	Starting current (%FLC)	600	
Load speed (rpm)			Starting torque (%FLT)	230	
$\frac{\text{Motor GD}^2 (\text{kgm}^2)}{1 \text{ GD}^2 (\text{kgm}^2)}$		18 CUSTOMED TO EUDNISH	Pull out torque (%FLT)		250
Load GD <sup>2</sup> (kgm <sup>2</sup> )		CUSTOMER TO FURNISH	Locked rotor withstand time (hot/cold) (sec)	15 / 30	
Load torque-speed	curve	Parabolic TS curve	Number of consecutive starts (hot/cold) (nos.)		2/3
		DI EACE ELIDNICH ALL ADOVE	provided Load GD2 = Motor GD2		
Starting time at rate	ed voltage (sec)	PLEASE FURNISH ALL ABOVE DETAILS			
Running Perform	ance	DETAILS			
Running Performance Efficiency class		IE2	Duty and designation	Continuous (S1)	
	np.rise by resistance (deg.C)	50 / 70	CDF/Equivalent starts per hour/FI		
•	ipilise by resistance (deg.c)	TEFC (TOTALLY ENCLOSED	· · ·	-	
Enclosure		FAN COOLED)	Insulation class / utilisation class on DOL	F/B	
Full load current (FLC) amps.		231	Rotor type (Squirrel Cage/ Slip ring )	Squirrel Cage	
Full load speed (rp		990	Rotor voltage/rotor current (RV/RA) (Volts/Amps)	Not a	pplicable
Full load torque (FLT) kg-m		130	Stator/rotor time constant (min)	144/194	
Efficiency in % at I	FL/0.75FL/0.5FL	94.6 94.6 93.8	Power factor at FL/0.75FL/0.5FL	0.84 0.8	1 0.7
Mechanical paran	neters		-		
Mounting		B5	Mounting dimensions		3A drawing
Shaft extention		Single cylindrical	Direction of rotation viewed from DE		ockwise
Degree of protectio	m	IP 55	Suitable for bidirectional rotation	Yes	
Method of cooling (TEFC/forced cooled/TESC)		TEFC (IC 411)	Paint type	Acrylic	
<u>.</u>	(1)	1175		-	
Net weight of moto	or (kgs.)	1175	Paint shade	RAL 5000	
Dominoa			Earthing provision (two terminals on stator body) Terminal box		Yes
Bearings Coupling (Direct/fl	lovible/Palt &		Terminai box		
Pulley/Gearbox)	exible/Belt &	Direct	Terminal box location when viewed from DE	As per GA drawing	
	llev (OD x width) mm	-	Direction of cable entry	As per GA drawing	
Dimenssions of pulley (OD x width) mm			•		
Bearings (roller/ba	ll/angular contact)	Ball /Ball	Cable size and type(Aluminium)	2R X 3C X 240 SQ MI	
Bearing size DE/N	DE	6319 C3 / 6319 C3	Earthing provision (one terminal in TB)		Yes
0			No of phases/Winding connection/number of	3 / DELTA / 6	
Type of lubrication	1	Unirex-N3 - GREASE	terminals	3 / D	ELIA/6
Accessories		·			
	simplex (w/o controller)		Arrow plate for direction of rotation		
3TDs - 1 number p	per bearing (w/o controller)		Double compression glands (main cable)		
Space heaters - sin	gle phase 50z, 230V		Double compression glands (Space		
		<u> </u>	heater/thermisters/RTDs)		
	, 1 number per phase		Brake (Type/voltage/torque)		
Additional T-Box f					
Additional namepla	aic	<u> </u>			
Notes:	values are subject to IS/IEC 4	50034-1 tolerances, unless otherwise s	specified		
		ated frequency condition and for DOL			
	and $GD^2$ assumed wherever no		statung condition.		
		provision of heavy duty relays is man	datory		
+) where starting th	s mandatory and HP is approx		uatory.		
5) Kilowatt ratine	vided are marked as "YES"	vinate.			
	vided are marked as TES				
, 0					
				Droposed 1	
				Prepared by	
				Prepared by Approved by Revison	

Project:		Contractor/Client		Date:	
Consultant		Package		Date.	