



Data sheet for motors

Manufacturer	Bharat Bijlee Ltd.		Customer			
Type of motor	3 phase Induction Motor		BBL Enquiry reference No			
Quantity			Customer P.O.Number			
Application	CUSTOMER TO FURNISH		W.O. No. / SAP No.			
Tag no.			Output kW / Pole		7.5	/ 2P
BBL type Ref.		MD13S2E5	Frame size		MJ132	
Installation details			Applicable standards (latest edition)			
Area classification (Safe / Hazardous)		Hazardous area	Performance: IS/IEC 60034-1 Maintenance IS:900		FLP Motors: IS/IEC 60079-1	
Location: indoor/outdoor/deck		Indoor	Dimensions: IS 1231/IS 2223/IS:8223			
Altitude (meters)		1000 or less	Vibrations: IS 12075			
			Noise level: IS 12065			
Hazardous area details			Supply conditions and permissible variations (grid supply)			
Area classification GAS (Zone 1/Zone 2)		ZONE I	Number of phases		Three	
Gas group		IIA, IIB	Voltage (Volts) and permissible variation		415	±10%
Temp.class		T5	Frequency (Hz) and permissible variation		50	±5%
Type of Explosion protection (FLP/Type 'a'/Type 'b')		Ex 'd'	Combined variation (absolute sum)		±10%	
Approving authority for hazardous area		If Mine application then DGMS else PESO				
Electrical parameters						
Starting performance						
Method of starting		DOL	Starting current (%FLC)		650	
Load speed (rpm)		CUSTOMER TO FURNISH	Starting torque (%FLT)		230	
Motor GD ² (kgm ²)		0.076	Pull out torque (%FLT)		300	
Load GD ² (kgm ²)		CUSTOMER TO FURNISH	Locked rotor withstand time (hot/cold) (sec)		8	/ 16
Load torque-speed curve		Parabolic TS curve	Number of consecutive starts (hot/cold) (nos.) provided Load GD2 = Motor GD2		2 / 3	
Starting time at rated voltage (sec)		PLEASE FURNISH ALL ABOVE DETAILS				
Running Performance						
Efficiency class		-	Duty and designation		Continuous (S1)	
Ambient temp./temp.rise by resistance (deg.C)		45 / 75	CDF/Equivalent starts per hour/FI		-	
Enclosure		TEFC (TOTALLY ENCLOSED FAN COOLED)	Insulation class / utilisation class on DOL		F/B	
Full load current (FLC) amps.		13.6	Rotor type (Squirrel Cage/ Slip ring)		Squirrel Cage	
Full load speed (rpm)		2920	Rotor voltage/rotor current (RV/RA) (Volts/Amps)		Not applicable	
Full load torque (FLT) kg-m		2.51	Stator/rotor time constant (min)		72/97	
Efficiency in % at FL/0.75FL/0.5FL		87.0 86.0 82.0	Power factor at FL/0.75FL/0.5FL		0.88	0.84 0.76
Mechanical parameters						
Mounting		B5	Mounting dimensions		Refer GA drawing	
Shaft extention		Single cylindrical	Direction of rotation viewed from DE		Clockwise	
Degree of protection		IP 55	Suitable for bidirectional rotation		Yes	
Method of cooling (TEFC/forced cooled/TESC)		TEFC (IC 411)	Paint type		Acid Alkali Proof	
Net weight of motor (kg)		82	Paint shade		632 as per IS 5	
			Earthing provision (two terminals on stator body)		Yes	
Bearings			Terminal box			
Coupling (Direct/flexible/Belt & Pulley/Gearbox)		Direct	Terminal box location when viewed from DE		As per GA drawing	
Dimenssions of pulley (OD x width) mm		-	Direction of cable entry		As per GA drawing	
Bearings (roller/ball/angular contact)		Ball /Ball	Cable size and type(Aluminium)		1R X 3C X 16 SQ MM	
Bearing size DE/NDE		6208 2Z C3/6208 2Z C3	Earthing provision (one terminal in TB)		Yes	
Type of lubrication		LITHIUM SOAP BASE GREASE	No of phase/winding connection/number of terminals		3 / DELTA / 6	
Accessories						
RTDs - 3 numbers simplex(w/o controller)			Arrow plate for direction of rotation			
BTDs - 1 number per bearing(w/o controller)			Double compression glands (main cable)			
Space heaters - single phase 50z, 230V			Double compression glands (Space heater/Thermisters/RTDs)			
Thermisters - PTC			Brake (Type/voltage/torque)			
Additional T-Box for Accessories						
Additional nameplate						
Notes:						
1) All performance values are subject to IS/IEC 60034-1 tolerances, unless otherwise specified.						
2) Performance values are at rated voltage and rated frequency condition and for DOL starting condition.						
3) Motor GD ² = Load GD ² assumed wherever not mentioned.						
4) Where starting time is more than 10 seconds, provision of heavy duty relays is mandatory.						
5) Kilowatt rating is mandatory and HP is approximate.						
6) Accessories provided are marked as "YES"						
					Prepared by	
					Approved by	

				Revision	
Project:		Contractor/Client		Date:	
Consultant		Package			