Manufacturer	Bharat Bijlee Ltd.		Customer			
Type of motor	3 phase Induction Motor		BBL Enquiry reference No			
Quantity	CUCTOME		Customer P.O.Number			
Application			W.O. No. / SAP No.	195	1	6D
Гад no. ЗBL type Ref.		MD20L613	Output kW / Pole Frame size	18.5	/ MJ200	6P
nstallation deta	ils		Applicable standards (latest edition)		IVIJ 200	
	on (Safe / Hazardous)	Hazardous area		FI P Mot	ors: IS/IEC	60079-
Location: indoor/		Indoor	Dimensions: IS 1231/IS 2223/IS:8223		015. 10/1LC	00077-
		1000 or less	Vibrations: IS 12075			
			Noise level: IS 12075			
Hazardous area	details		Supply conditions and permissible variations (grid	supply)		
•	on GAS (Zone 1/Zone 2)	ZONE I	Number of phases		Three	
Gas group		IIA, IIB	Voltage (Volts) and permisible variation	415 ±10%		0%
Femp.class		T5	Frequency (Hz) and permissible variation	$50 \pm 5\%$		
rype or Explosion protection		Ex 'd'	Combined variation (absolute sum)	±10%		
Approving authority for hazardous area		If Mine application then DGMS else PESO				
Electrical param Starting perform						
Method of startin		DOL	Starting current (%FLC)		580	
Load speed (rpm)	0	CUSTOMER TO FURNISH	Starting torque (%FLT)	260		
Motor GD ² (kgm	-	1	Pull out torque (%FLT)	230		
Load GD ^{2} (kgm ^{2}	•	CUSTOMER TO FURNISH	Locked rotor withstand time (hot/cold) (sec)	12	/	24
			Number of consecutive starts (hot/cold) (sec)		,	<i>∟</i> −⊤
Load torque-speed curve		Parabolic TS curve PLEASE FURNISH ALL ABOVE	provided Load GD2 = Motor GD2	2/3		
Starting time at ra	ated voltage (sec)	DETAILS				
Running Perform	nance			1		
Efficiency class		-	Duty and designation	Continuous (S1)		(S1)
Ambient temp./temp.rise by resistance (deg.C)		45 / 75	CDF/Equivalent starts per hour/FI	-		
Inclosure		TEFC (TOTALLY ENCLOSED FAN COOLED)	Insulation class / utilisation class on DOL	F/B		
Full load current (FLC) amps.		34.0	Rotor type (Squirrel Cage/ Slip ring)	Squirrel Cage		ige
Full load speed (rpm)		975	Rotor voltage/rotor current (RV/RA) (Volts/Amps)	Not applicable		ble
Full load torque (18.5	Stator/rotor time constant (min)		144/194	
•	t FL/0.75FL/0.5FL	91.1 91.0 88.0	Power factor at FL/0.75FL/0.5FL	0.83	0.78	0.70
Mechanical para	imeters			1		
Mounting		B8	Mounting dimensions	Refer GA drawing		0
Shaft extention	-	Single cylindrical	Direction of rotation viewed from DE	Clockwise		e
Degree of protection		IP 55	Suitable for bidirectional rotation	Yes		
Method of coolin	g (TEFC/forced cooled/TESC)	TEFC (IC 411)	Paint type	Acid Alkali Proof		Proof
Net weight of mo	otor (kg)	275	Paint shade	632 as per IS 5		S 5
			Earthing provision (two terminals on stator body)		Yes	
Bearings			Terminal box	1		
Coupling (Direct/flexible/Belt & Pulley/Gearbox)		Direct	Terminal box location when viewed from DE	As per GA drawing		
•	oulley (OD x width) mm	-	Direction of cable entry	As per GA drawing		
Bearings (roller/ball/angular contact)		Ball /Ball	Cable size and type(Aluminium)	2R X 3C X 50 SQ M		SQ MM
Bearing size DE/NDE		6212 C3/6212 C3	Earthing provision (one terminal in TB)	Yes		
		LITHIUM SOAP BASE GREASE			3 / DELTA	/ 6
	rs simplex(w/o controller)		Arrow plate for direction of rotation			
	r per bearing(w/o controller)		Double compression glands (main cable)			
Space heaters - single phase 50z, 230V			Double compression glands (Space			
Thermisters - PTC			heater/Thermisters/RTDs) Brake (Type/voltage/torque)			
Additional T-Box	x for Accessories					
	olate			1		

2) Performance values are at rated voltage and rated frequency condition and for DOL starting condition. 3) Motor $GD^2 = Load GD^2$ assumed wherever not mentioned.

4) Where starting time is more than 10 seconds, provision of heavy duty relays is mandatory.

5) Kilowatt rating is mandatory and HP is approximate.

6) Accessories provided are marked as "YES"

Prepared by	
Approved by	

			Revison	
Project:	Contractor/Client		Date:	
Consultant	Package			