

 <b>Bharat Bijlee</b>		<i>Data sheet for motors</i>	
<b>Manufacturer</b>	<b>Bharat Bijlee Ltd.</b>	<b>Customer</b>	
<b>Type of motor</b>	<b>3 Phase Induction Motor</b>	<b>BBL Enquiry reference No</b>	
<b>Quantity</b>		<b>Customer P.O.Number</b>	
<b>Application</b>	<b>CUSTOMER TO FURNISH</b>	<b>W.O. No. / SAP No.</b>	
Tag no.		Output kW / pole	22 / 4P
BBL type tef.	2J18L485	Frame size	MJ180
<b>Installation details</b>		<b>Applicable standards (latest edition)</b>	
Area classification (Safe / Hazardous)	Hazardous	Performance: IS/IEC 60034-1 Maintenance IS:900	FLP Motors: IS/IEC 60079-1
Location: indoor/outdoor/deck	Indoor	Dimensions: IS 1231/IS 2223/IS:8223	
Altitude (meters)	1000 or less	Vibrations: IS 12075	
		Noise level: IS 12065	
<b>Hazardous area details</b>		<b>Supply conditions and permissible variations (grid supply)</b>	
Area classification GAS (Zone 1/Zone 2)	ZONE I	Number of phases	Three
Gas group	IIA, IIB	Voltage (Volts) and permissible variation	415 ±10%
Temp.class	T5	Frequency (Hz) and permissible variation	50 ±5%
Type of Explosion protection (FLP/Type 'e'/Type 'n')	Ex d	Combined variation (absolute sum)	±10%
Approving authority for hazardous area	If Coal Mine application then DGMS else PESO		
<b>Electrical parameters</b>			
<b>Starting performance</b>			
Method of starting	DOL	Starting current (%FLC)	650
Load speed (rpm)	CUSTOMER TO FURNISH	Starting torque (%FLT)	260
Motor GD <sup>2</sup> (kgm <sup>2</sup> )	0.512	Pull out torque (%FLT)	290
Load GD <sup>2</sup> (kgm <sup>2</sup> )	CUSTOMER TO FURNISH	Locked rotor withstand time (hot/cold) (sec)	10 / 20
Load torque-speed curve	Parabolic TS curve	Number of consecutive starts (hot/cold) (nos.) provided Load GD2 = Motor GD2	2 / 3
Starting time at rated voltage (sec)	PLEASE FURNISH ALL ABOVE DETAILS		
<b>Running Performance</b>			
Efficiency class	IE2	Duty and designation	Continuous (S1)
Ambient temp./temp.rise by resistance (deg.C)	45 / 75	CDF/Equivalent starts per hour/FI	-
Enclosure	TEFC (TOTALLY ENCLOSED FAN COOLED)	Insulation class / utilisation class on DOL	F/B
Full load current (FLC) amps.	39.3	Rotor type (Squirrel Cage/ Slip ring )	Squirrel Cage
Full load speed (rpm)	1460	Rotor voltage/rotor current (RV/RA) (Volts/Amps)	Not applicable
Full load torque (FLT) kg-m	14.6	Stator/rotor time constant (min)	108/146
Efficiency in % at FL/0.75FL/0.5FL	91.6 91.6 91.0	Power factor at FL/0.75FL/0.5FL	0.85 0.82 0.72
<b>Mechanical parameters</b>			
Mounting	B5	Mounting dimensions	Refer GA drawing
Shaft extention	Single cylindrical	Direction of rotation viewed from DE	Clockwise
Degree of protection	IP 55	Suitable for bidirectional rotation	Yes
Method of cooling (TEFC/forced cooled/TEFC)	TEFC (IC 411)	Paint type	Acid Alkali Proof
Net weight of motor (kgs.)	226	Paint shade	632 as per IS 5
		Earthing provision (two terminals on stator body)	Yes
<b>Bearings</b>		<b>Terminal box</b>	
Coupling (Direct/flexible/Belt & Pulley/Gearbox)	Direct	Terminal box location when viewed from DE	As per GA drawing
Dimenssions of pulley (OD x width) mm	-	Direction of cable entry	As per GA drawing
Bearings (roller/ball/angular contact)	Ball /Ball	Cable size and type(Aluminium)	2R X 3C X 50 SQ MM
Bearing size DE/NDE	6310 2Z C3 / 6310 2Z C3	Earthing provision (one terminal in TB)	Yes
Type of lubrication	LITHIUM SOAP BASE GREASE	No of phases/Winding connection/number of terminals	3 / DELTA / 6
<b>Accessories</b>			
RTDs - 3 numbers simplex (w/o controller)		Arrow plate for direction of rotation	
BTDs - 1 number per bearing (w/o controller)		Double compression glands (main cable)	
Space heaters - single phase 50z, 230V		Double compression glands (Space heater/thermistors/RTDs)	
Thermistors - PTC , 1 number per phase		Brake (Type/voltage/torque)	
Additional T-Box for Accessories			
Additional nameplate			
<b>Notes:</b>			
1)All performance values are subject to IS/IEC 60034-1 tolerances, unless otherwise specified.			
2)Performance values are at rated voltage and rated frequency condition and for DOL starting condition.			
3)Motor GD <sup>2</sup> = Load GD <sup>2</sup> assumed wherever not mentioned.			
4)Where starting time is more than 10 seconds, provision of heavy duty relays is mandatory.			
5)Kilowatt rating is mandatory and HP is approximate.			
6) Accessories provided are marked as "YES"			
		Prepared by	
		Approved by	
		Revision	
<b>Project:</b>		<b>Contractor/Client</b>	
<b>Consultant</b>		<b>Package</b>	
		Date:	

