Manufacturer	Bharat Bijlee Ltd.		Customer			
Type of motor	3 phase Induction Motor		BBL Enquiry reference No			
Quantity			Customer P.O.Number			
			W.O. No. / SAP No.			
Tag no.			Output kW / Pole	30	/	4P
BBL type Ref.		MD20L435	Frame size		MJ200	
Installation detail	ils		Applicable standards (latest edition)			
Area classification (Safe / Hazardous)		Hazardous area	Performance: IS/IEC 60034-1 Maintenance IS:900) FLP Motors: IS/IEC 60079-1		
Location: indoor/outdoor/deck		Indoor	Dimensions: IS 1231/IS 2223/IS:8223			
Altitude (meters)		1000 or less	Vibrations: IS 12075			
			Noise level: IS 12065			
Hazardous area			Supply conditions and permissible variations (grid	l supply)		
	n GAS (Zone 1/Zone 2)	ZONE I	Number of phases		Three	
Gas group		IIA, IIB	Voltage (Volts) and permisible variation	415 ±10%		
Temp.class		T5	Frequency (Hz) and permissible variation	50 ±5%		%
$\mathbf{\overline{EI D}} \mathbf{\overline{T_{VDA}}} = \mathbf{\overline{D}} \mathbf{\overline{T_{VDA}}} $		Ex 'd'	Combined variation (absolute sum)		±10%	
Approving authority for hazardous area		If Mine application then DC else PESO	GMS			
Electrical param	eters					
Starting perform						
Method of starting		DOL	Starting current (%FLC)	600		
Load speed (rpm)	_	CUSTOMER TO FURNI	SH Starting torque (%FLT)	_	260	
Motor GD^2 (kgm	2)	0.86	Pull out torque (%FLT)		250	
Load GD ^{2} (kgm ^{2}		CUSTOMER TO FURNI	SH Locked rotor withstand time (hot/cold) (sec)			24
	, 		Number of consecutive starts (hot/cold) (nos.)			
Load torque-spee	ed curve	Parabolic TS curve		brovided Load $GD2 = Motor GD2$ 2		
		PLEASE FURNISH ALL AF				
Starting time at ra	ated voltage (sec)	DETAILS				
Running Perform	nance					
Efficiency class		_	Duty and designation	Continuous (S1)		S 1)
Ambient temp./temp.rise by resistance (deg.C)		45 / 75	5 CDF/Equivalent starts per hour/FI	-		
Enclosure		TEFC (TOTALLY ENCLO	SED Insulation class / utilisation class on DOL	F/B		
		FAN COOLED)				
Full load current (FLC) amps.		51.6	Rotor type (Squirrel Cage/ Slip ring)	Squirrel Cage		
Full load speed (rpm)		1465	Rotor voltage/rotor current (RV/RA) (Volts/Amps)	Not applicable		
Full load torque (FLT) kg-m		19.9	Stator/rotor time constant (min)	144/194		0.77
•	t FL/0.75FL/0.5FL	92.0 92.0 90	.0 Power factor at FL/0.75FL/0.5FL	0.88	0.84	0.77
Mechanical para	imeters	D <i>5</i>				•
Mounting		B5	Mounting dimensions	Refer GA drawing		
Shaft extention	tion	Single cylindrical	Direction of rotation viewed from DE	Clockwise		
Degree of protect	UOII	IP 55	Suitable for bidirectional rotation	Yes		
Method of coolin	g (TEFC/forced cooled/TESC)	TEFC (IC 411)	Paint type	Acid Alkali Proof		
Net weight of mo	otor (kg)	305	Paint shade	632 as per IS 5		
			Earthing provision (two terminals on stator body)	Yes		
Bearings			Terminal box			
Coupling (Direct/	/flexible/Belt &					• •
Pulley/Gearbox)		Direct	Terminal box location when viewed from DE	As per GA drawing		
,	oulley (OD x width) mm	-	Direction of cable entry	As per GA drawing		
Bearings (roller/ball/angular contact)		Ball /Ball	Cable size and type(Aluminium)	2R X 3C X 50 SQ MM		
Bearing size DE/NDE		6212 2Z C3/6212 2Z C3	3 Earthing provision (one terminal in TB)	Yes		
Type of lubrication		LITHIUM SOAP BASE GR		3 / DELTA / 6		[′] 6
Accessories						
	rs simplex(w/o controller)		Arrow plate for direction of rotation			
BTDs - 1 number per bearing(w/o controller)			Double compression glands (main cable)			
	ingle phase 50z, 230V		Double compression glands (Space			
Champiotore Dr	$\overline{\mathbf{C}}$		heater/Thermisters/RTDs)			
Thermisters - PT			Brake (Type/voltage/torque)			
Additional T-Box Additional namer	x for Accessories					
	X + + + + / X			1		

2) Performance values are at rated voltage and rated frequency condition and for DOL starting condition.

3) Motor $GD^2 = Load GD^2$ assumed wherever not mentioned.

4) Where starting time is more than 10 seconds, provision of heavy duty relays is mandatory.

5) Kilowatt rating is mandatory and HP is approximate.

6) Accessories provided are marked as "YES"

Prepared by	
Approved by	

			Revison	
Project:	Contractor/Client		Date:	
Consultant	Package			