Manufacturer Fype of motor	Bharat Bijlee Ltd.3 phase Induction Motor		Customer BBL Enquiry reference No			
Quantity			Customer P.O.Number			
Application			W.O. No. / SAP No.			
Гаg no.			Output kW / Pole	3.7	/	2P
BBL type Ref.		MD10L213	Frame size		MJ100	
Installation detail	ils		Applicable standards (latest edition)			
Area classification	n (Safe / Hazardous)	Hazardous area	Performance: IS/IEC 60034-1 Maintenance IS:900	FLP Moto	ors: IS/IEC 6	0079-
Location: indoor/	outdoor/deck	Indoor	Dimensions: IS 1231/IS 2223/IS:8223			
Altitude (meters)		1000 or less	Vibrations: IS 12075			
× /			Noise level: IS 12065			
Hazardous area	details		Supply conditions and permissible variations (grid	supply)		
Area classification	n GAS (Zone 1/Zone 2)	ZONE I	Number of phases		Three	
Gas group	· · · · · · · · · · · · · · · · · · ·	IIA, IIB	Voltage (Volts) and permisible variation	415	±10	%
Temp.class		T5	Frequency (Hz) and permissible variation	50	±5%	
rypé or Explosio	•	Ex 'd'	Combined variation (absolute sum)		±10%	•
(EL D/Type 'o'/Type 'n') Approving authority for hazardous area		If Mine application then DGMS else PESO			_10/0	
Electrical param						
Starting perform				1		
Method of starting		DOL	Starting current (%FLC)	650		
Load speed (rpm)		CUSTOMER TO FURNISH	Starting torque (%FLT)	280		
Motor GD^2 (kgm ²)		0.0188	Pull out torque (%FLT)		300	
Load GD^2 (kgm ²	() (i) (i) (i) (i) (i) (i) (i) (i) (i) (CUSTOMER TO FURNISH	Locked rotor withstand time (hot/cold) (sec)	15	/	30
Load torque-spee		Parabolic TS curve	Number of consecutive starts (hot/cold) (nos.) provided Load GD2 = Motor GD2		2/3	
Starting time at ra	ated voltage (sec)	PLEASE FURNISH ALL ABOVE DETAILS	E			
Running Perform	nance			1		
Efficiency class		-	Duty and designation	C	ontinuous (S	S1)
Ambient temp./temp.rise by resistance (deg.C)		45 / 75	CDF/Equivalent starts per hour/FI			
Enclosure		TEFC (TOTALLY ENCLOSED FAN COOLED)	Insulation class / utilisation class on DOL	F/B		
Full load current		7.1	Rotor type (Squirrel Cage/ Slip ring)	Squirrel Cage		
Full load speed (r	rpm)	2900	Rotor voltage/rotor current (RV/RA) (Volts/Amps)	Not applicable		le
Full load torque (FLT) kg-m		1.25	Stator/rotor time constant (min)	108/146		
Efficiency in % at	t FL/0.75FL/0.5FL	85.0 83.0 78.0	Power factor at FL/0.75FL/0.5FL	0.85	0.80	0.70
Mechanical para	imeters					
Mounting		B3	Mounting dimensions	Re	fer GA draw	ving
Shaft extention		Single cylindrical	Direction of rotation viewed from DE	Clockwise		
Degree of protection		IP 55	Suitable for bidirectional rotation	Yes		
Method of coolin	g (TEFC/forced cooled/TESC)	TEFC (IC 411)	Paint type	Acid Alkali Proof		
Net weight of mo	tor (kg)	62	Paint shade	632 as per IS 5		5
Bearings			Earthing provision (two terminals on stator body) <i>Terminal box</i>	632 as per IS 5 Yes		
Coupling (Direct/ Pulley/Gearbox)	flexible/Belt &	Direct	Terminal box location when viewed from DE	As per GA drawing		
v ,	ulley (OD x width) mm	_	Direction of cable entry	As per GA drawing		
Bearings (roller/b	all/angular contact)	Ball /Ball	Cable size and type(Aluminium)	1R X 3C X 16 SQ MM		
Bearing size DE/I	NDE	6206 2Z C3/6206 2Z C3	Earthing provision (one terminal in TB)	Yes		
Type of lubrication	Dn	LITHIUM SOAP BASE GREASE		3	/ DELTA /	6
Accessories						
RTDs - 3 number	rs simplex(w/o controller)		Arrow plate for direction of rotation			
	per bearing(w/o controller)		Double compression glands (main cable)			
•	ingle phase 50z, 230V		Double compression glands (Space heater/Thermisters/RTDs)			
Thermisters - PTO	С		Brake (Type/voltage/torque)			
Additional T-Box	t for Accessories					
Additional namep	olate					
						

2) Performance values are at rated voltage and rated frequency condition and for DOL starting condition.

3) Motor $GD^2 = Load GD^2$ assumed wherever not mentioned.

4) Where starting time is more than 10 seconds, provision of heavy duty relays is mandatory.

5) Kilowatt rating is mandatory and HP is approximate.

6) Accessories provided are marked as "YES"

Prepared by	
Approved by	

			Revison	
Project:	Contractor/Client		Date:	
Consultant	Package			