

4

3

2

1

ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE SPECIFIED

SCALE - N.T.S.

Minimum distance for efficient cooling
of motor (To be maintained by user)

F



F

E

E

D

D



Fixing



General

IEC Frame	Pole	A	B	B1	C	H	K	AB	BB	AA	BA	BC	BA1	HA	HC	HD	L	LV	AC
160M	2	254	210	254	108	160	15	314	294	60	70	23	115	20	317	472	704	60	314

T Box

Shaft

V	O	O1	q	S2	D	E	F	GA	I	d5
404	252	151	365	M32x1.5P	42	110	12	45	105	M16



Notes:-

- 1) Ringed dimensions are as per IS:1231/IEC60072
- 2) Terminal box can be rotated in 360 deg in steps of 90 deg.

B

B

Customer		Project	
P.O. No.		Consultant	
kW/Pole		Client/Contractor	
Frame		Package	
SO No.		Tag no's	

A

A

NAME	DATE	TITLE:	
DRN	YCJ	07.04.2015	DIMENSION DRAWING
CHD			3PH SQUIRREL CAGE, TEFC (FOOT MOUNTED) FLAME PROOF(Ex'd') INDUCTION MOTOR
APPD			
Bharat Bijlee AIROLI, NAVI MUMBAI		DRG. No:	D16M231TC

4

3

2

1