




FRAME SIZE	CABLE ENTRY
MJ 160	M32X1.5P (TWIN)
MJ 180	M40X1.5P (TWIN)
MJ 200	M40X1.5P (TWIN)



- NOTE: (a) (b) (c) (d) (e)

- 1) STUD SIZE = M8
- 2) STUD TO GLAND PLATE DISTANCE = 242mm.
- 3) PVC HOOD FOR CABLE GLAND NOT IN BBL SCOPE.
- 4) CABLE LUGS NOT IN BBL SCOPE.
- 5) TERMINAL BOX MATERIAL = CI.
- 6) TERMINAL BOX IS ROTATABLE BY 360° IN THE STEP OF 90°.

1								
1	DESCRIPTION	ITEM	CODE	MATL.	DRG. NL.	PATTERN NL.	WT.	
DRG. NL.						OR SIZE	LB.	
			(2) REVISED FOR TIF-5, RST 2802/11 (3) SCALE ENTER CHANGED AS PER TIF/LEC 60079-1-2007 PAGE 20.03.03 (4) REVISED FOR TIF-SRK-050213					
DATE	NAME	APP'L	TITLE	V/L NL.	SCALE			
DRN 17/12/83	PJM		TERMINAL BOX ARRANGEMENT		NTS			
TCD			(MT 160 TO MT200)					
CHD 17/12/83								
BHARAT BILEE LTD.				DRG. NL.	FR. SIZE			
KALMA				REF.	MT 160			
					MT 180			
					MT 200			

TERMINAL BOX WITHOUT SEALING BOX FOR CABLE ENTRY. ④