



WARNING INSCRIPTION "DO NOT OPEN WITH POWER ON" CAST
INTEGRALLY ON TERMINAL BOX COVER BY RAISED LETTERS



SECTION 'A-A'



NOTE:

- 1) STUD SIZE = M8
- 2) STUD TO GLAND PLATE DISTANCE = 274mm.
- 3) PVC HOOD FOR CABLE GLAND NOT IN BBL SCOPE.
- 4) CABLE LUGS NOT IN BBL SCOPE.
- 5) TERMINAL BOX MATERIAL = CI.
- 6) TERMINAL BOX IS ROTATABLE BY 360° IN THE STEP OF 90°.

FRAME SIZE	CABLE ENTRY
MJ 160	M32X1.5P (TWIN)
MJ 180	M40X1.5P (TWIN)
MJ 200	M40X1.5P (TWIN)

1								
QTY	DESCRIPTION	ITEM	CODE	DRG. NO.	PATTERN NO.	Wt.		
					DR. SIZE	kg.		
				Q REVISIED FOR TIF-6, PER 1907/11				
				Q REVISIED FOR TIF-6, PAST 2507/11				
				Q COABLE ENTRY CHANGED AS PER 15/02/09 60079-1-2007 PAGE 200312				
				Q REVISIED FOR TIF --SR-- 0506/13				
		DATE	NAME	APPL.	TITLE	W.O.No.	SCALE	
		DRN 1107/10	JAG		TERMINAL BOX ARRANGEMENT		NTS	
		TCD			(M160 TO M200)			
		CHD.						
	BHARAT BILEE LTD.				DRG. NO.	FR. SIZE		
	KALMA				TBAD18LC018	MJ160-MJ180		
					REF.	MJ200		

ALL DIMENSIONS IN MM

TERMINAL BOX WITH SEALING BOX FOR CABLE ENTRY. ④